

Herz Fig No TMV+15 or +22

WRAS Approved Herzshield thermostatic mixing valves shall be approved by the TMV scheme and meet the requirements for a type 3 valve, complying with the NHS Model Engineering Specification DO8. Valves shall be supplied with flat-faced angled union couplings incorporating isolation valves, strainers and integral, removable check valves; factory preset to 38°C but with simple adjustment and locking system for each onsite application. Valves shall have a nickel plated DZR Copper alloy body and connections suitable for 15mm or 22mm pipework, rated PN10. Valves must be suitable for the following applications HP-B; HP-S; HP-W; HP-T44; HPT46; LP-B; LP-S; LP-W.

Valves must be installed and maintained in accordance with the relevant specification. The supplied installation and maintenance log sheet must be completed and updated as necessary.