

## **Herz Fig No DR-T-90**

Manual valves mounted on the flow shall have a double regulating function, with tamperproof pre-setting by use of a special tool, allowing accurate balancing of the system and fitted with a hand wheel. Removal of the double regulating insert must be achievable while the system is live and under full working conditions using a dedicated tool, allowing subsequent replacement or servicing. The valve shall be capable of being interchangeable with, and/or upgradeable to, a thermostatic valve, rated PN10. The valve manufacturer shall provide a five year fully comprehensive warranty, covering parts, labour and consequential loss.