Herz Fig No RL-1

parts, labour and consequential loss.

Return isolating valves shall be operated with a hexagon key to close the valve and have a flat knurled sealing cap to avoid tampering, rated PN10. The valve manufacturer shall provide a five year fully comprehensive warranty, covering